

Spring/Pre-Uptime Checklist

DATE OF INSPECTION	
INSPECTOR NAME	
UNIT MODEL TYPE	
UNIT SERIAL NUMBER	
TRAILER NUMBER	
OTHER REFERENCE	

CONDENSER INSPECTION

Are there any obstructions or debris in the condenser? YES / NO

Have these obstructions been cleaned? YES / NO

Any notes or follow-up task from the cleaning process?

Example: stubborn obstructions need pressure water/air cleaner

Cleaning Reminder: Clean from inside (non-airside) to outside (airside), air/water pressure level below 120 bars, min. 15 cm distance, if needed use NEUTRAL soap or detergent.

EXPANSION TANK INSPECTION

Are there any degradation or damage in the expansion tank ? YES / NO

Which steps are applied for this condition? *Date of replacement/installment*

☐ Expansion Tank (all) has been replaced _____

☐ Expansion Tank Cap has been replaced _____

☐ Expansion Tank Cover installed (preventive) _____

BELT TENSIONERS INSPECTION

Are the belt tensioners still performing well? YES / NO

Are there any damages or degradation on the belt tensioners? YES / NO

Does the belt tensioner need replacements? YES / NO

Note down the part number of the belt tensioners that need replacement: